



NOTES:

1. BELOW GRADE UNSUPPORTED WALL HEIGHT NOT TO EXCEED 10'-0"
2. BELOW GRADE BACKFILL HEIGHT NOT TO EXCEED 9'-6"
3. BELOW GRADE DURISOL WALL FORM MUST ACCCOMODATE MINIMUM 6.25" THICK CONCRETE CORE
4. ABOVE GRADE UNSUPPORTED WALL HEIGHT NOT TO EXCEED 10'-0"
5. ABOVE GRADE DURISOL WALL FORM MUST ACCCOMODATE MINIMUM 5'-0" THICK CONCRETE CORE

TYPICAL SECTION

TITLE: DURISOL FLOOR DETAIL NO. 16					JOB NO:	
PROJECT: DETAILS - DURISOL WALLFORM SYSTEM						SCALE: 1 :10
DATE: 11.12.02	REVISED:	DRAWN BY: VA	CHECKED BY: VA	FILE NAME: DFL-13		DWG. NO: DFL-16