



NOTES:

1. BELOW GRADE UNSUPPORTED WALL HEIGHT NOT TO EXCEED 9'-0"
2. BELOW GRADE BACKFILL HEIGHT NOT TO EXCEED 9'-0"
3. BELOW GRADE DURISOL WALL FORM MUST ACCCOMODATE MINIMUM 6.5"mm THICK CONCRETE CORE
4. ABOVE GRADE UNSUPPORTED WALL HEIGHT NOT TO EXCEED 10'-0"
5. ABOVE GRADE DURISOL WALL FORM MUST ACCCOMODATE MINIMUM 4 7/8" THICK CONCRETE CORE

TYPICAL SECTION

TITLE: FIRST FLOOR DETAIL						JOB NO:
PROJECT: DURISOL DETAILS						SCALE: 1 :10
DATE: 11.27.03	REVISED:	DRAWN BY: VA	CHECKED BY: VA	FILE NAME: DFL-17		DWG. NO: DFL-17